

---

---

# MEMORANDUM

## Public Works Department – City of Middleton

---

---

DATE: February 1, 2012  
TO: All Holders of the City of Middleton Standard Specifications  
FROM: Shawn Stauske, City Engineer  
SUBJECT: **Revisions to City Specifications and Contract Documents**

---

The Standard Specifications and Construction Contract Documents for the City of Middleton, dated June of 2004, have been amended as follows. Affected pages are not being mailed, but are available on the City's web site. Effective immediately, the following changes should be made to various bidding and contract documents for public works projects in the City of Middleton:

**Table of Contents (Page i)**

The note at the bottom of the page has been updated to indicate that the standard documents have been revised to be current as of February 1<sup>st</sup>, 2012.

**Section 400 Water Main**

Section 401.C has been modified to clarify that AWWA C509 is (cast iron) and that C515 (ductile iron) may also be used.

Section 402.J provision has been added specifying the requirement for "Water Service Records". With this added provision the following provisions have been re-lettered.

Section 402.N has been modified from 30' to now be 20'.

**Preparation Of Contract Documents**

Pages P-6 to P-9 have been added.

**Standard Detail Drawings**

Drawing 100-1 has been modified from a 6" minimum depth to now be a 12" minimum depth. Also Gradation number 1 base course material to now be Open graded stone 6" minimum, 12 " maximum.

Drawings 300-2, 300-3, 300-7 & 300-8 have been modified from an ASTM designation of D-1248 to now be ASTM designation D-4976.

Drawing 300-6 has been modified to include specs for a Neenah Foundry inlet frame grate no. R-2500.

Affected Pages:

Detail Drawings 100-1,	Page P-6 to P-9	Page i
Detail Drawings 300-2,-3,-6,-7,-8	Section 400-2	

---

---

CITY OF MIDDLETON  
7426 HUBBARD AVENUE - MIDDLETON, WI 53562  
ph. (608)827-1081 fax (608)827-1080 sstauske@ci.middleton.wi.us